

Permit: 1102045

Status: 11 Permit Application submitted.
Waiting for approval.

Location: 10854 LIMEBERRY DRIVE
Sub Div: EMB LKS - PARCEL R-1

Builder: 107079 - PRESTIGE SOLAR INC
Owner: MOHALL

Inspection Status

Insp. Num.	Insp. Type.	STATUS	FEE	Action Available	Description	Seq.	Ordered Date/Time	Scheduled Date/Time	Inspected Date/Time
3310	SOPN	No Activity		Request	3310 - SOLAR PANEL	5			
3990	PLFI	No Activity		Request	3990 - PLUMBING FINAL	6			

Plan Review Status

Type	Status	Reviewer	Started	Stopped	Notes
ADMN	N		//	//	
PLUM	P	Wiesel	05/17/2011	05/17/2011	
STRU	N	Tony	//	//	
STRU	F	Tony	05/24/2011	05/24/2011	05/24/2011 09:31:55 AM Added By: Tony Notes: REj . What is the max. uplift pressure that the panels and anchors were tested for? What is the uplift pressure for zone one on this project.
ZONE	N		//	//	

Change Permit Number

Page generated:05/24/2011 10:48:38

Automated Inspection Request System (AIRS) By

Vetrol Data Systems, Inc. Copyright 2001-09 Ver 4.2.4
2500 13th Ave Vero Beach, FL 772-562-1621

I cannot locate this information of the plan.